



U.S. Chemical Safety and Hazard Investigation Board

OFFICE OF GENERAL COUNSEL

Memorandum

To: Board Members

From: Steven Messer
Acting General Counsel

STEVEN
MESSER

Digitally signed by
STEVEN MESSER
Date: 2026.01.20
15:18:54 -05'00'

Cc: Charles Barbee
Adam Henson
Leadership Team

Subject: Board Action Report – Notation Item 2026-14| Recommendation to Intercontinental Terminals Company (ITC) (2019-01-I-TX-R3) from the Intercontinental Terminals Company (ITC) Tank Fire investigation (2019-01-I-TX)

Date: January 20, 2026

On January 20, 2026, the Board approved Notation Item 2026-15, thereby designating Recommendation 2019-01-I-TX-R3 to Intercontinental Terminals Company (ITC) from the Intercontinental Terminals Company (ITC) Tank Fire investigation (2019-01-I-TX) with the status of Closed – Acceptable Action.

Voting Summary – Notation Item 2026-14

Disposition: APPROVED

Disposition date: January 20, 2026

Approve	Disapprove	Calendar	Not Participating	Date
---------	------------	----------	----------------------	------

S. Johnson	X			1/20/2026
S. Owens	X			1/20/2026



U. S. Chemical Safety and Hazard Investigation Board

RECOMMENDATION STATUS CHANGE

SUMMARY

Report:	Intercontinental Terminals Company (ITC) Tank Fire
Recommendation Number:	2019-01-I-TX-R3
Date Issued:	July 6, 2023
Recipient:	Intercontinental Terminals Company
New Status:	Closed – Acceptable Action
Date of Status Change:	January 20, 2026

Recommendation Text:

Install flammable gas detection systems with associated alarm functions in product storage and transfer areas at the ITC Deer Park terminal where flammable substance releases could occur. Develop and implement a response plan and operator training for actions to take when an alarm sounds.

Board Status Change Decision:

A. Rationale for Recommendation

On March 17, 2019, a loss of containment and massive fire occurred at the Intercontinental Terminals Company (ITC) terminal facility in Deer Park, Texas. The incident resulted from the seal failure of a pump operating in conjunction with Tank 80-8, an 80,000-barrel (3.36 million gallon) above ground atmospheric storage tank containing a mixture of naphtha and butane.

The incident did not result in any injuries. However, the fire burned for three days and spread from Tank 80-8 to the other fourteen tanks located within the same containment area. All fifteen tanks were destroyed. On March 22, 2019, the containment area wall partially collapsed releasing approximately 500,000 barrels (21 million gallons) of a mixture of petroleum products, firefighting foam, and water into Tucker Bayou and adjacent waterways including the Houston Ship Channel.

The U.S. Chemical Safety and Hazard Investigation Board (CSB) investigated the incident and found several safety issues including ineffective mechanical integrity and maintenance practices for the facility's product transfer pumps, a lack of safety systems at the facility's 80s tank farm, and a lack of regulatory coverage under the Occupational Safety and Health Administration's (OSHA's) Process Safety Management (PSM) standard and the U.S. Environmental Protection Agency's (EPA's) Risk Management Program (RMP) rule for the contents of Tank 80-8 at the time of the incident. As a result of these findings, the CSB issued five recommendations to ITC. This status change summary addresses CSB Recommendation No. 2019-01-I-TX-R1.

B. Response to the Recommendation

ITC notified the CSB that they completed the installation of LEL/flammable gas detectors in all storage and product transfer areas of their Deer Park terminal where releases could occur. ITC also updated their Integrated Contingency Plan and other pertinent documents to include actions to take in response to releases detected by the newly installed detectors. Upon review of the relevant documentation provided, the CSB concluded that ITC's actions satisfy all requirements of the recommendation.

C. Board Analysis and Decision

Based upon the information above, the Board voted to change CSB Recommendation No. 2019-01-I-TX-R3 to: "Closed – Acceptable Action."