



U. S. Chemical Safety and Hazard Investigation Board

RECOMMENDATION STATUS CHANGE

SUMMARY

Report:	Intercontinental Terminals Company (ITC) Tank Fire
Recommendation Number:	2019-01-I-TX-R1
Date Issued:	July 6, 2023
Recipient:	Intercontinental Terminals Company
New Status:	Closed – Acceptable Action
Date of Status Change:	July 25, 2025

Recommendation Text:

Develop and implement a process safety management system for the ITC Deer Park terminal applicable to all atmospheric storage tanks and associated equipment in highly hazardous chemical service. The program should follow industry guidance provided in publications such as the American Petroleum Industry's API STD 2610, Design, Construction, Operation, Maintenance, and Inspection of Terminal and Tank Facilities and the Center for Chemical Process Safety's Guidelines for Risk Based Process Safety.

Board Status Change Decision:

A. Rationale for Recommendation

On March 17, 2019, a loss of containment and massive fire occurred at the Intercontinental Terminals Company (ITC) terminal facility in Deer Park, Texas. The incident resulted from the seal failure of a pump operating in conjunction with Tank 80-8, an 80,000-barrel (3.36 million gallon) above ground atmospheric storage tank containing a mixture of naphtha and butane.

The incident did not result in any injuries. However, the fire burned for three days and spread from Tank 80-8 to the other fourteen tanks located within the same containment area. All fifteen tanks were destroyed. On March 22, 2019, the containment area wall partially collapsed releasing approximately 500,000 barrels (21 million gallons) of a mixture of petroleum products, firefighting foam, and water into Tucker Bayou and adjacent waterways including the Houston Ship Channel.

The U.S. Chemical Safety and Hazard Investigation Board (CSB) investigated the incident and found several safety issues including ineffective mechanical integrity and maintenance practices for the facility's product transfer pumps, a lack of safety systems at the facility's 80s tank farm, and a lack of regulatory coverage under the Occupational Safety and Health Administration's (OSHA's) Process Safety Management (PSM) standard and the U.S. Environmental Protection Agency's (EPA's) Risk Management Program (RMP) rule for the contents of Tank 80-8 at the time of the incident. As a result of these findings, the CSB issued five recommendations to ITC. This status change summary addresses CSB Recommendation No. 2019-01-I-TX-R1.

B. Response to the Recommendation

ITC developed and implemented a PSM program applicable to all atmospheric storage tanks and associated equipment in highly hazardous chemical service based upon OSHA 3909 "*Process Safety Management for Storage Facilities*" which is an appropriate industry guidance document for a storage facility like ITC. Upon review of the information ITC provided that supported each element of OSHA 3909, the CSB concluded that ITC has implemented the requirements of the recommendation.

C. Board Analysis and Decision

Based upon the information above, the Board voted to change CSB Recommendation No. 2019-01-I-TX-R1 to: "Closed – Acceptable Action."